



NATA Accredited Laboratory

Accreditation No: 15305

Accredited for compliance with  
ISO/IEC 17025 - Testing

**Laminex**<sup>®</sup>

a division of Laminex Group Pty Ltd ABN 98 004 093 092

## The Laminex Group Technology Centre

Postal Address: PO BOX 720, Wendouree, Vic 3355

Address: 22 Trewin St, Wendouree, Vic 3355

Telephone: (03) 5337 3613

Fax: (03) 5337 3647

**Test Report No.  
2331600**

**Date of Issue  
27/09/2023**

**Client:  
Laminex New Zealand - Technical Services  
810 Great South Road,  
Penrose, Auckland 1061,  
New Zealand**

This test report shall not be reproduced, except in full,  
without written approval from The Laminex Group Technology Centre

The material contained in this report is confidential to the entity identified as 'Client' above.

As the sample(s) have been provided by the client, the results contained in this report apply only to the sample(s) as received.

Test Report No. 2331600

Date of Issue: 27/09/2023

Laminex Sample Reference No.	31600
Client Sample Reference No.	<b>Melteca MR PB</b>
Product Description: (Supplied by client)	Melteca decorated MR PB
Surface Treatment	Low Pressure Melamine (LPM)
Receive Date:	5/09/2023
Condition:	Good
Testing Performed Date(s):	14/09/2023
<b>Specification Standard</b>	<b>AS/NZS 1859.1:2017</b>
<b>Product Classification</b>	<b>Moisture resistant particleboard</b>

Test Report No. 2331600

Date of Issue: 27/09/2023

MDF				
Test	Method	Unit	Mean	STD Dev
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.09	0.00

Comments
Test sample meets E1 formaldehyde classification.

Approved Signatory:

