

Emission Test Certificate

Wednesday 05th June 2019

Supplier: The Laminex Group Technology Centre (22 Trewin Street, Wendouree, 3355, VIC)

Sample Description: Laminex Strandsarking

Date Tested: March 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

| Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B | Laminex Strandsarking |
|--|--|
| Total Volatile Organic Compound Emission Rate Limit: | Total Volatile Organic Compound |
| ≤0.500 mg/m²/hr | Emission Rate: 0.038 mg/m ² /hr |

Dr. Vyt Garnys PhD, BSc(Hons) AIMM, ARACI, ISIAQ ACA, AIRAH, FMA Managing Director and Principal Consultant

Nick Joy BSc(Hons) Consultant

Tour

Tuan Duong B.Eng. (Chemical) Consultant

CV190489