



NATA Accredited Laboratory

Accreditation No: 15305

Accredited for compliance with  
ISO/IEC 17025 - Testing

**Laminex**<sup>®</sup>

a division of Laminex Group Pty Ltd ABN 98 004 093 092

## The Laminex Group Technology Centre

Postal Address: PO BOX 720, Wendouree, Vic 3355

Address: 22 Trewin St, Wendouree, Vic 3355

Telephone: (03) 5337 3613

Fax: (03) 5337 3647

**Test Report No.**  
**2127778A**

**Date of Issue**  
**19/01/22**

**Client:**  
**Laminex New Zealand - Taupo Plant**  
**177 Centennial Drive,**  
**Rotokawa 3378,**  
**New Zealand**

This test report shall not be reproduced, except in full,  
without written approval from The Laminex Group Technology Centre

The material contained in this report is confidential to the entity identified as 'Client' above.

As the sample(s) have been provided by the client, the results contained in this report apply only to  
the sample(s) as received.

Test Report No. 2127778A

Date of Issue: 19/01/22

Laminex Sample Reference No.	27775, 27776, 27777, 27778, 27851, 27852, 27853, 27854, 28127, 28128, 28129, 28130
Client Sample Reference No.	<b>PB Flooring Trial 21004</b>
Product Description: (Supplied by client)	20mm Super Fine Particle Board Flooring Trial
Surface Treatment	None/Raw
Receive Date:	18/05/21 (27775 - 27778) 03/06/21 (27851 - 27854) 28/07/21 (28127 - 28130)
Condition:	Good
Testing Performed Date(s):	04/06/21 (27775 - 27778) 23/06/21 (27851 - 27854) 13/08/21 (28127 - 28130)
Specification Standard	<b>AS/NZS 1860.1:2017</b>
Product Classification	<b>Flooring Class 2</b>

Test Report No. 2127778A

Date of Issue: 19/01/22

Flooring Class 2			27778	27775	27776	27777	27853	27854
Test	Method	Unit	21004-2	21004-4	21004-5	21004-8	21004B-3	21004B-4
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.00	1.09	1.15	1.00	1.17	1.07

Flooring Class 2			27851	27852	28127	28128	28129	28130
Test	Method	Unit	21004B-7	21004B-8	21004C-3	21004C-4	21004C-5	21004C-6
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.04	1.10	1.52	1.21	1.17	1.32

Flooring Class 2			Percentiles						AS/NZS 1860.1:2017 Limit (Class 2)	
Test	Method	Unit	Grand Mean	STD Dev	5	95	number of samples (n)	k <sub>n</sub> -value		
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	1.2	0.1	0.9	1.4	12	1.802	≤	1.5

Comments

Approved Signatory:  
 Research & Development Technician (Martin Stewart)

