

Emission Test Certificate

Wednesday, November 23rd, 2022

Supplier Laminex New Zealand (810 Great South Road, PENROSE, 1061, Auckland, New Zealand).

Product Name SuperPine Panel

Product Description SuperPine MDF Panel 20 mm thickness

Date Tested 11th November 2022 (Tested through Foray Laboratory – NATA Accreditation 1231)

Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days)

<p>New Zealand Green Building Council</p> <p>Green Star Design & As Built V1.1 13.1.2B & 13.2</p> <p>Green Star Interiors V1.1 - 12.1.2B</p>	<p>SuperPine Panel</p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate*: 0.052 mg/m²/hr</p>

**The stated result was averaged of three different specimens provided by Laminex New Zealand*



Dr. Vyt Garnys
 Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant



Dr. Tuan Duong
 Ph.D., B.Eng. (Chemical)
 Senior Consultant

Issue date: 23/11/2022

Expiry date: 23/11/2027

P22110013